

Memo



Stantec

To: Stu White
Banwell Architects

From: Robert F Kischko
North Springfield VT

File: 1957100053

Date: September 27, 2006

Reference: Green Woodlands – Addenda 2 (Electrical)

This addendum forms a part of the Contract Documents and modifies the original Specifications dated August 31st (Addendum No. 1) Bidders must acknowledge receipt of this addendum in the space provided on the Bid form. **Failure to do so may subject the Bidder to disqualification.**

This addendum to the Contract Documents consists of 1 page.

The Contract Documents are amended as follows:

1. Drawing E1.02 – delete a total of 6 telephone receptacles in the bedrooms – 2 each bedroom. Coordinate with Owner/Architect on exact location of telephone outlet to remain. Bedroom 08 will have 2 outlets, bedroom 10 and 13 shall only have one.
2. Drawing E1.02 – Add circuit for the 1/3 HP motor for wood dumbwaiter, see Architectural plans for locations. Provide wiring and all related devices as per manufacturers instructions. Circuit AC-37, 3/4" conduit with 2#10, 1#10G.
3. Contractor shall carry an allowance of \$15,000 (fifteen thousand dollars) for an Energy Interface Controller and related wiring to coordinate the hydro, solar (battery charger function) and generator.